

Отчет о потреблении тепловой энергии и теплоносителя за Сентябрь 2021 г.

Потребитель:

ул. Комсомольская, д.22

Тип прибора:

ТСРВ-024

Номер прибора:

1104241

Теплосистема:

2

Дата	W1, Гкал	m1, т	t1, °C	P1, МПа	W2, Гкал	m2, т	t2, °C	P2, МПа	W3, Гкал	m3, т	t3, °C	P3, МПа	W4, Гкал	m4, т	t4, °C	P4, МПа
01.09.21	1.481	27.256	64.54	0.90	0.815	18.607	53.48	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
02.09.21	1.436	25.998	65.31	0.90	1.066	24.503	53.21	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
03.09.21	1.508	27.521	64.80	0.90	0.819	19.039	52.82	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
04.09.21	1.466	27.023	64.38	0.90	0.733	17.488	51.64	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
05.09.21	1.531	28.147	64.43	0.90	0.812	19.145	52.21	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
06.09.21	1.442	26.765	64.13	0.90	0.703	16.744	51.58	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
07.09.21	1.463	26.832	64.51	0.90	0.758	17.988	51.98	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
08.09.21	1.454	26.726	64.51	0.90	0.721	17.260	51.52	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
09.09.21	1.544	28.139	64.86	0.90	0.818	19.333	52.16	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
10.09.21	1.502	27.403	64.86	0.90	0.766	17.786	52.88	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
11.09.21	1.562	28.450	64.90	0.90	0.823	19.161	52.79	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
12.09.21	1.495	27.183	65.01	0.90	0.761	17.778	52.66	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
13.09.21	1.534	27.825	65.19	0.90	1.280	29.287	53.43	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
14.09.21	1.453	26.295	65.20	0.90	0.769	17.972	52.63	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
15.09.21	1.477	26.796	65.16	0.90	0.832	19.148	53.31	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
16.09.21	1.471	26.911	64.64	0.90	0.781	18.527	51.99	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
17.09.21	1.526	28.161	64.19	0.90	0.798	19.002	51.84	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
18.09.21	1.472	27.031	64.48	0.90	0.791	18.759	52.05	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
19.09.21	1.530	28.344	63.95	0.90	0.792	19.157	51.23	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
20.09.21	1.471	27.160	64.11	0.90	0.757	18.366	51.07	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
21.09.21	1.485	27.448	64.12	0.90	0.781	18.831	51.37	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
22.09.21	1.424	26.108	64.55	0.90	0.748	18.098	51.13	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
23.09.21	1.403	27.058	61.64	0.90	0.759	19.083	49.73	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
24.09.21	1.324	26.764	59.50	0.90	0.685	17.901	48.11	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
25.09.21	1.402	27.844	60.30	0.90	0.760	19.404	49.07	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
26.09.21	1.362	27.066	60.28	0.90	0.726	18.528	49.08	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
27.09.21	1.380	27.370	60.47	0.90	0.740	18.774	49.20	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
28.09.21	1.359	27.196	59.99	0.90	0.694	17.749	48.90	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
29.09.21	1.391	27.595	60.37	0.90	0.761	19.392	49.13	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
30.09.21	1.355	27.019	60.14	0.90	0.732	18.447	49.47	0.50	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
Среднее:	1.457	27.248	63.48		0.793	19.042	51.39		0.000	0.000	0.00		0.000	0.000	0.00	
Итого:	43.702	817.436			23.782	571.256			0.000	0.000			0.000	0.000		

Ответственный за учет тепловой энергии:

 Д.С. Яabloвнев

Отчет принят _____ 200 г. _____

Программа ЗАО "ВЗЛЕТ"
www.vzljet.ru